

Amendment No. 2 Approved on ... ~~1999-12-09~~
to SLS 948 : Part 1 : 1991

**SRI LANKA STANDARD SPECIFICATION FOR THREE-PIN PLUGS
SOCKET-OUTLETS AND SOCKET-OUTLET ADAPTORS**

PART 1 : PLUGS, SOCKET-OUTLETS AND ADAPTORS

Page 12

Replace existing Table 9 with the following table.

TABLE 9 - Dimensions of pillar terminals

Current rating A	Nominal diameter of hole for conductor mm	Minimum thickness of wall where clamping screw passes through mm	ISO size of clamping screw
(1)	(2)	(3)	(4)
5	3.0	1.6	M2.5
15	4.0	3.2	M3.5

Page 15

Replace existing Table 12 with the following table

TABLE 12 - Dimensions of pillar terminals

Current rating A	Nominal diameter of hole for conductor mm	Minimum thickness of wall where clamping screw passes through mm	ISO size of clamping screw
(1)	(2)	(3)	(4)
5	3.6	1.6	M3
15	4.4	3.2	M3.5

unw

sls948pi.doc (dpi)- (99-09-24)