

**AMENDMENT NO. 3 APPROVED ON 2011-07-08
TO SLS 1206: 2000**

**SRI LANKA STANDARD SPECIFICATION
FOR CABLE TRUNKING MADE OF INSULATING MATERIAL**

Clause 5.3 Dimensions

Delete the contents immediately after the title and substitute with the following:

The external dimensions (i.e. the width and the height), in millimeters, of rectilinear cable trunking shall be selected from any combination of the following numbers.

10.0, 12.5, 14.0, 16.0, 20.0, 25.0, 32.0, 37.5, 40.0, 50.0, 75.0, 100, 150.

Tolerance of external dimensions shall be ± 0.5 mm.
