

AMENDMENT NO. 1 APPROVED ON 1988-06-07

SLS 614:Part 2:1983 SPECIFICATION FOR POTABLE WATER - BACTERIOLOGICAL REQUIREMENTS

Page 4

Clause 3.1.2

Amend to read as follows:

"None of the samples examined shall contain more than 3 coliform organisms per 100 ml".

Clause 3.2.1

Amend to read as follows:

"None of the samples examined shall contain more than 10 coliform organisms per 100 ml".