

AMENDMENT NO. 01 APPROVED ON 1996-05-23 TO SLS 750 : PART 1 : 1986**SRI LANKA STANDARD SPECIFICATION FOR ALUMINIUM CONDUCTORS
FOR OVERHEAD POWER TRANSMISSION PURPOSES**

1. **Insert the following new Clause immediately after 5.2.3.**

6 PACKAGING AND MARKING

The conductor shall be wound on reels or drums, and each drum or reel shall bear a durable tag marked with the following:

- a) Manufacturer's name or trade name;
- b) Size of conductor;
- c) Net and gross mass of conductor;
- d) Length of conductor; and
- e) Overall dimensions of drum.

2. **Re-number the existing clause 6 TESTING as given below.**

Title	Existing Clause Number	New Clause Number
TESTING	6	7
Selection of test Samples	6.1	7.1
Place of testing	6.2	7.2
Tensile test	6.3	7.3
Wrapping	6.4	7.4
Resistivity test	6.5	7.5